

## LAE9400LX




ELECTROZEMPER S.A. Avda. de la Ciencia s/n.
Parque Ind. Avanzado
13005 Ciudad Real. Spain.
Tel.: +34 902 11 11 97
Fax: +34 902 11 11 97
info@zemper.com

### Graphic reference

**ARIAN** 





Control System: AutoTest

Luminaire: Self-Contained

Standards: EN-60598-1, EN-60598-2-22, EN-62034 Certification: CE

Supply: 230V 50Hz<1.0W

Maintained mode consumption: - W

Non-maintained mode consumption: 1,0 W

Working temperature: 0-40°C Emergency lamp: 12 x LED 0.5W Emergency lumen output: 390 lm Maintained lumen output: - Im Battery: 3.2V-1.5Ah LFP

Mode: Non-maintained Power factor: - % Signaling Luminaire: -LED temperature: 4000°K

Duration: 1 h Remote control: Yes Charging time: 12 h

### **Mechanical characteristics**

Housing: Polycarbonate Diffuser: Matted Polycarbonate

Suitable for flammable surfaces: Yes

IP/IK: IP65/IK10

Finish: White RAL9003

Weight: 0,64KG

### ATEX Envelope:

### Photometric curve

## Interdistance

9,99 m	9,99 m
11,03 m	11,03 m
11,92 m	11,92 m
12,68 m	12,68 m
	11,03 m 11,92 m



## LAE9400LX



ELECTROZEMPER S.A.
Avda. de la Ciencia s/n.
Parque Ind. Avanzado
13005 Ciudad Real. Spain.
Tel.: +34 902 11 11 97
Fax: +34 902 11 11 97
in fo@zemper.com

### Installation characteristics

**ARIAN** 

Maintained luminaires use 3 terminals to enable / disable the maintained mode.
Installation with mounting plate.
Possibility of installation in:
Ceiling/Wall surface.

Possibility of connection with: Surface tube wiring.

It has 3 pre-marked entries for PG-11 cable glands (not included), for mounting with surface pipe.

### **Operating characteristics**

The luminaire has status LEDs, which indicates:

Status of the battery charging circuit.

Battery status (duration)

Emergency status function.

Test status.

Microprocessor controlled luminaire that performs periodic and automatic tests.

Functional test every 7 days.

Duration test every 365 days.

The test result is shown in the status indicator LEDs.

Remote control input that allows:

Put on Standby without power supply.

Restart in emergency status without power supply.

Switch on in emergency status (more than 24 h of charge)

Manual and remote duration test. (more than 24 hours of charge).

Date and time programming of the tests.

Reset of the luminaire status.

General Envelo	pe data			



# LAE9400LX



ELECTROZEMPER S.A.
Avda. de la Ciencia s/n.
Parque Ind. Avanzado
13005 Ciudad Real. Spain.
Tel.: +34 902 11 11 97
Fax: +34 902 11 11 97
in fo@zemper.com
www.zemper.com

### Accessories

