

# **LML9170LXP3**




ELECTROZEMPER S.A.
Avda. de la Ciencia s/n.
Parque Ind. Avanzado
13005 Ciudad Real. Spain.
Tel.: +34 902 11 11 97
Fax: +34 902 11 11 97
info@zemper.com

### Graphic reference

SPAZIO NANO



#### Dimensions



Control System: AutoTest

Luminaire: Self-Contained

**Standards:** EN-60598-1, EN-60598-2-22, EN-62034

Certification: CE, CIVIL

DEFENSE



#### Electrical characteristics

Supply: 230V 50Hz<2.5W

 $\label{eq:maintained} \begin{tabular}{ll} \textbf{Maintained mode consumption: } 2.5~W \\ \begin{tabular}{ll} \textbf{Non-maintained mode consumption: } 0.9~W \\ \end{tabular}$ 

Working temperature: 0-40°C Emergency lamp: 1XLEDS 3W Emergency lumen output: 165 lm Maintained lumen output: 100 lm

Battery: 3.2V-1.8Ah LFP

Class: II

Mode: M/NM Power factor: - % Signaling Luminaire: -LED temperature: 4000°K

**Duration:** 3 h **Remote control:** Yes **Charging time:** 12 h

### **Mechanical characteristics**

**Envelope:** Polycarbonate **Diffuser:** Antipanic Lens

Suitable for flammable surfaces: Yes


IP/IK: IP42/IK04

Finish: White RAL9003

Weight: 0,48KG

## ATEX Envelope:

## Photometric curve



# Interdistance

Installation height		
2,0 m	7,91 m	8,00 m
2,5 m	8,67 m	8,77 m
3,0 m	9,28 m	9,38 m
3,5 m	9,75 m	9,87 m



# **LML9170LXP3**



ELECTROZEMPER S.A.
Avda. de la Ciencia s/n.
Parque Ind. Avanzado
13005 Ciudad Real. Spain.
Tel.: +34 902 11 11 97
Fax: +34 902 11 11 97
info@ zemper.com
www.zemper.com

#### Installation characteristics

SPAZIO NANO

Maintained luminaires use 3 mains supply inputs (L, L1, N) to enable / disable the maintained mode
Luminaires made up of a spotlight + electrical equipment with batteries (Self-contained luminaires).
Possibility of installation in:

On suspended ceiling.

Recessed ceiling (Slat ceilings) with accessory (included).

Continuous rail.

#### **Operating characteristics**

The luminaire has status LEDs, which indicates:

Status of the battery charging circuit.

Battery status (duration)

Emergency status function.

Test status.

Microprocessor controlled luminaire that performs periodic and automatic tests.

Functional test every 7 days.

Duration test every 365 days.

The test result is shown in the status indicator LEDs.

Remote control input that allows:

Put on Standby without power supply.

Restart in emergency status without power supply.

Switch on in emergency status (more than 24 h of charge)

Manual and remote duration test. (more than 24 hours of charge).

Date and time programming of the tests.

Reset of the luminaire status.

General Envelope data		