


# LML9250LXP



ELECTROZEMPER S.A. Avda. de la Ciencia s/n. Parque Ind. Avanzado 13005 Ciudad Real. Spain. Tel.: +34 902 11 11 97 Fax: +34 902 11 11 97 in fo @ z em per.com w w w.z em per.com

### Graphic reference






### **Electrical characteristics**

Supply: 230V 50Hz<2.8W	Class: II	
Maintained mode consumption: 2.8 W	Mode: M/NM	
Non-maintained mode consumption: 0.9 W	Power factor: - %	
Working temperature: 0-40°C	Signaling Luminaire: -	
Emergency lamp: 1XLEDS 3W	LED temperature: 4000°K	
Emergency lumen output: 250 lm	Duration: 1 h	
Maintained lumen output: 150 lm	Remote control: Yes	
Battery: 3.2V-1.5Ah LFP	Charging time: 12 h	


# Mechanical characteristics Envelope: Polycarbonate Diffuser: Antipanic Lens Suitable for flammable surfaces: Yes ATEX Envelope:

### Photometric curve



### Interdistance

Installation height		
2,0 m	8,90 m	8,98 m
2,5 m	9,81 m	9,91 m
3,0 m	10,57 m	10,69 m
3,5 m	11,21 m	11,33 m



## LML9250LXP



 $\begin{array}{l} {\sf ELECTROZEMPER} {\sf S.A.} \\ {\sf Avda. de la Ciencia s/n.} \\ {\sf Parque Ind. Avanzado} \\ {\sf 13005 Ciudad Real. Spain.} \\ {\sf rel:. +34 902 11 11 97} \\ {\sf Fax: +34 902 11 11 97} \\ {\sf rat o @ zemper.com} \\ {\sf ww.zemper.com} \end{array}$ 

### Installation characteristics

Luminaires made up of a spotlight + electrical equipment with batteries (Self-contained luminaires). Possibility of installation in: On suspended ceiling. Recessed ceiling (Slat ceilings) with accessory (included). Continuous rail. **Operating characteristics** The luminaire has status LEDs, which indicates: Status of the battery charging circuit. Battery status (duration) Emergency status function. Test status. Microprocessor controlled luminaire that performs periodic and automatic tests. Functional test every 7 days. Duration test every 365 days. The test result is shown in the status indicator LEDs. Remote control input that allows: Put on Standby without power supply.

Maintained luminaires use 3 mains supply inputs (L, L1, N) to enable / disable the maintained mode.

Restart in emergency status without power supply. Switch on in emergency status (more than 24 h of charge) Manual and remote duration test. (more than 24 hours of charge). Date and time programming of the tests. Reset of the luminaire status.

### General Envelope data