


# LML9251LDPW




ELECTROZEMPER S.A.
Avda. de la Ciencia s/n.
Parque Ind. Avanzado
13005 Ciudad Real. Spain.
Tel.: +34 902 11 11 97
Fax: +34 902 11 11 97
info@zemper.com

### Graphic reference

SPAZIO NANO



### Dimensions



Control System: AutoTest Centralized Wireless

**Standards:** EN-60598-1, EN-60598-2-22, EN-62034

Luminaire: Self-Contained

Certification: CE, ENEC



### Electrical characteristics

Supply: 230V 50Hz<2.8W

 $\label{eq:maintained} \begin{tabular}{ll} \textbf{Maintained mode consumption: } 2.8~W\\ \begin{tabular}{ll} \textbf{Non-maintained mode consumption: } 0.9~W\\ \end{tabular}$ 

Working temperature: 0-40°C Emergency lamp: 1 x LED 3W Emergency lumen output: 250 lm Maintained lumen output: 150 lm

Battery: 3.2V-1.5Ah LFP

Class: II

Mode: M/NM Power factor: - % Signaling Luminaire: -LED temperature: 4000°K

**Duration:** 1 h **Remote control:** No **Charging time:** 12 h

## **Mechanical characteristics**

**Envelope:** Polycarbonate **Diffuser:** Escape Lens

Suitable for flammable surfaces: Yes

IP/IK: IP42/IK04

Finish: White RAL9003

Weight: 0,22KG

# ATEX Envelope:

# Photometric curve

# 90° 90° 60° 160

# Interdistance

Installation height		
2,0 m	7,38 m	23,89 m
2,5 m	7,87 m	26,57 m
3,0 m	8,21 m	28,45 m
3,5 m	8,43 m	30,15 m



# LML9251LDPW



ELECTROZEMPER S.A.
Avda. de la Ciencia s/n.
Parque Ind. Avanzado
13005 Ciudad Real. Spain.
Tel.: +34 902 11 11 97
Fax: +34 902 11 11 97
in fo @ ze m p e r . c o m
w w w w . z e m p e r . c o m

### Installation characteristics

SPAZIO NANO

Maintained luminaires use 3 mains supply inputs (L, L1, N) to enable / disable the maintained mode
Luminaires made up of a spotlight + electrical equipment with batteries (Self-contained luminaires).
Possibility of installation in:

On suspended ceiling.

Recessed ceiling (Slat ceilings) with accessory (incluided).

Continuous rail.

## **Operating characteristics**

The luminaire has status LEDs, which indicates:

Status of the battery charging circuit.

Battery status (duration)

Emergency status function.

Test status.

Microprocessor controlled luminaire

The luminaire can be connected to a control unit.

When the luminaire is installed without a control unit, it performs periodic and automatic tests.

Functional test every 7 days.

Duration test every 365 days.

The test result is shown in the status indicator LEDs.

Wireless communication that allows: Communication with Control unit by wireless communication with a 868Mhz frequency system.

Gener	al Envelope data			