

# **LSM3170LWP3**




ELECTROZEMPER S.A. Avda. de la Ciencia s/n.
Parque Ind. Avanzado
13005 Ciudad Real. Spain.
Tel.: +34 902 11 11 97
Fax: +34 902 11 11 97
in fo@zemper.com

## Graphic reference

**Datasheet** SPAZIO ON





Standards: EN-60598-1, EN-60598-2-22, EN-62034, ETSI EN 303 446-1 V1.2.1

Certification: CE



Supply: 230V 50Hz<2.5W

Maintained mode consumption: 2,5 W Non-maintained mode consumption: 0,9 W

Working temperature: 0-40°C Emergency lamp: 1 x LED 3W Emergency lumen output: 165 lm Maintained lumen output: 100 lm

Battery: 3.2V-1.8Ah LFP

Mode: M/NM Power factor: - % Signaling Luminaire: -LED temperature: 4000°K

Duration: 3 h Remote control: No Charging time: 12 h

# **Mechanical characteristics**

Housing: Polycarbonate Diffuser: Antipanic Lens

Suitable for flammable surfaces: Yes

IP/IK: IP42/IK04

Finish: White RAL9003

Weight: 0,19KG

## ATEX Envelope:

### **Photometric curve**

## Interdistance

| Installation<br>height |         |         |
|------------------------|---------|---------|
| 2,0 m                  | 7,41 m  | 7,41 m  |
| 2,5 m                  | 8,47 m  | 8,47 m  |
| 3,0 m                  | 9,43 m  | 9,43 m  |
| 3,5 m                  | 10,25 m | 10,25 m |



# **LSM3170LWP3**



ELECTROZEMPER S.A. Avda. de la Ciencia s/n. Parque Ind. Avanzado 13005 Ciudad Real. Spain. Tel:: +34 902 11 11 97 Fax: +34 902 11 11 97 rax: +32 em per.com

### Installation characteristics

SPAZIO ON

Non-maintained luminaires use 4 terminals (2xL + 2xN) for supply connection.

Maintained luminaires use 5 terminals (2xL + 2xN + L1) to enable / disable the maintained mode.

Installation with mounting plate.

Possibility of installation in:

Ceiling/Wall surface.

Recessed ceiling (with installation accessory)

Possibility of connection with:

Recessed wiring.

Surface tube wiring (max. M20)

### **Operating characteristics**

The luminaire has status LEDs, which indicates:

Status of the battery charging circuit.

Battery status (duration)

Emergency status function.

Test status.

Microprocessor controlled luminaire

The luminaire can be connected to a control unit.

When the luminaire is installed without a control unit, it performs periodic and automatic tests.

Functional test every 7 days.

Duration test every 365 days.

The test result is shown in the status indicator LEDs.

Wireless communication that allows: Communication with Control unit by wireless communication with a 2.4Ghz frequency system.

| General Envelope data |  |
|-----------------------|--|
|                       |  |
|                       |  |
|                       |  |
|                       |  |
|                       |  |
|                       |  |
|                       |  |
|                       |  |



# Datasheet SPAZIO ON

# **LSM3170LWP3**



ELECTROZEMPER S.A.
Avda. de la Ciencia s/n.
Parque Ind. Avanzado
13005 Ciudad Real. Spain.
Tel.: +34 902 11 11 97
Fax: +34 902 11 11 97
in fo @ z e m p e r . c o m
w w w w . z e m p e r . c o m

### Accessories















