

SPAZIO PLUS





ELECTROZEMPER S.A. ELECTROZEMPER S.A. Avda. de la Ciencia s/n. Parque Ind. Avanzado 13005 Ciudad Real. Spain. Tel:: +34 902 11 11 97 Fax: +34 902 11 11 97 in fo@zemper.com www.zemper.com





LSP3255LDPW



 $\begin{array}{l} {\sf ELECTROZEMPER} {\sf S.A.} \\ {\sf Avda. de la Ciencia s/n.} \\ {\sf Parque Ind. Avanzado} \\ {\sf 13005 Ciudad Real. Spain.} \\ {\sf rel:. +34 902 11 11 97} \\ {\sf Fax: +34 902 11 11 97} \\ {\sf rat o @ zemper.com} \\ {\sf ww.zemper.com} \end{array}$

Installation characteristics

Non-maintained luminaires use 4 terminals (2xL + 2xN) for supply connection. Maintained luminaires use 5 terminals (2xL + 2xN + L1) to enable / disable the maintained mode. Installation with mounting plate. Possibility of installation in: Ceiling/Wall surface. Recessed ceiling (with installation accessory) Possibility of connection with: Recessed wiring. Surface tube wiring (max. M20)

Operating characteristics

The luminaire has status LEDs, which indicates:
Status of the battery charging circuit.
Battery status (duration)
Emergency status function.
Test status.
Microprocessor controlled luminaire
The luminaire can be connected to a control unit.
When the luminaire is installed without a control unit, it performs periodic and automatic tests.
Functional test every 7 days.
Duration test every 365 days.
The test result is shown in the status indicator LEDs.
Wireless communication that allows: Communication with Control unit by wireless communication with a 868Mhz frequency system.

General Envelope data



LSP3255LDPW

ALC0011



ELECTROZEMPER S.A. Avda. de la Ciencia s/n. Parque Ind. Avanzado 13005 Ciudad Real. Spain. Tel.: +34 902 11 11 97 Fax: +34 902 11 11 97 in fo @ z em per.com w w w.z em per.com

Accessories













