

SPAZIO LUZ TRACK

# LUZ6400LWP




ELECTROZEMPER S.A.
Avda. de la Ciencia s/n.
Parque Ind. Avanzado
13005 Ciudad Real. Spain.
Tel.: +34 902 11 11 97
Fax: +34 902 11 11 97
in fo @ ze m p e r . c o m
w w w w . z e m p e r . c o m

### Graphic reference



### Dimensions



Control System: SmartZ Luminaire: Self-Contained

**Standards:** EN-60598-1, EN-60598-2-22, EN-62034, ETSI EN 303 446-1 V1.2.1 Certification: CE

### Electrical characteristics

Supply: 230V 50Hz<3.0W

 $\label{eq:maintained} \begin{tabular}{ll} \textbf{Maintained mode consumption: } 3,0 \ W \\ \begin{tabular}{ll} \textbf{Non-maintained mode consumption: } -W \\ \end{tabular}$ 

Working temperature: 0-40°C
Emergency lamp: 12xLED 0.5W
Emergency lumen output: 425 lm
Maintained lumen output: 250 lm

Battery: 3.2V-1.5Ah LFP

Class: || Mode: -

Power factor: - %
Signaling Luminaire: LED temperature: 4000°K

**Duration:** 1 h **Remote control:** No **Charging time:** 12 h

## **Mechanical characteristics**

Housing: Polycarbonate

**Diffuser:** Transparent Polycarbonate **Suitable for flammable surfaces:** Yes


Weight: 0,23KG

Finish: White RAL9003

IP/IK: IP20/IK04

ATEX Envelope:

## Photometric curve



## Interdistance

Installation height		
2,0 m	9,80 m	9,78 m
2,5 m	10,98 m	10,96 m
3,0 m	11,92 m	11,91 m
3,5 m	12,74 m	12,73 m



# LUZ6400LWP



ELECTROZEMPER S.A.
Avda. de la Ciencia s/n.
Parque Ind. Avanzado
13005 Ciudad Real. Spain.
Tel.: +34 902 11 11 97
Fax: +34 902 11 11 97
in fo @ z e m p e r . c o m
w w w w . z e m p e r . c o m

### Installation characteristics

nstallation characteristics			
Installation possibilities in:			
Electrical rail.			
Compatible with ONETRACK UL 3 circuits			
Compatible with EUROSTANDARD tracks			
Compatible with EUROSTANDARD tracks			
erating characteristics			
erating characteristics			
The luminaire has status LEDs, which indicates:			

Status of the battery charging circuit.

Battery status (duration)

Emergency status function.

Test status.

Microprocessor controlled luminaire

The luminaire can be connected to a control unit.

When the luminaire is installed without a control unit, it performs periodic and automatic tests.

Functional test every 7 days.

Duration test every 365 days.

The test result is shown in the status indicator LEDs.

Wireless communication that allows: Communication with Control unit by wireless communication with a 2.4Ghz frequency system.

General Envelope data	