


### Graphic reference



### Dimensions



**Control System:** DALI2

**Luminaire:** Self-Contained

**Standards:** EN-60598-1,  
EN-60598-2-22, EN-62034, EN  
61347-2-7, EN 61347-2-13, EN  
62386

**Certification:** CE, ENEC,  
CIVIL DEFENSE, DALI2



### Electrical characteristics

**Supply:** 230V 50Hz<4.5W

**Maintained mode consumption:** 4,5 W

**Non-maintained mode consumption:** 2,0 W

**Working temperature:** 0-40°C

**Emergency lamp:** 12 x LED 0.5W

**Emergency lumen output:** 300 lm

**Maintained lumen output:** 180 lm

**Battery:** 6.4V-1.5Ah LFP

**Class:** II

**Mode:** -

**Power factor:** - %

**Signaling Luminaire:** -

**LED temperature:** 4000°K

**Duration:** 3 h

**Remote control:** Yes

**Charging time:** 12 h

### Mechanical characteristics

**Housing:** Polycarbonate

**Diffuser:** Transparent Polycarbonate

**Suitable for flammable surfaces:** Yes


**ATEX Envelope:**

**IP/IK:** IP66/IK10

**Finish:** Transparent

**Weight:** 0,75KG

### Photometric curve



### Interdistance

**Installation height**



2,0 m	9,18 m	9,10 m
2,5 m	10,41 m	10,54 m
3,0 m	11,50 m	11,58 m
3,5 m	12,44 m	12,49 m

### Installation characteristics

Maintained luminaires have a selector bridge to enable / disable the maintained mode.

Possibility of installation in:

Ceiling/Wall surface.

Possibility of connection with:

Surface tube wiring.

It has 3 pre-marked entries for PG-11 cable glands (not included), for mounting with surface pipe.

### Operating characteristics

Bus available for DALI2 communication.

The luminaire has a status LED, which indicates:

Green LED: OK

Yellow LED flashing: Battery charging or battery connection failure.

LED off: Emergency operation failure or mains failure or defective LED or defective unit.

### General Envelope data

### Accessories

#### APF600



ACC. PICTO. DIANA/XENA IP66  
UNIVERSAL PERSON + ARROW