


LXF9150LDP3WT




ELECTROZEMPER S.A.
Avda. de la Ciencia s/n.
Parque Ind. Avanzado
13005 Ciudad Real. Spain.
Tel.: +34 902 11 11 97
Fax: +34 902 11 11 97
in fo@zemper.com

Graphic reference

XENA FLAT



Dimensions



Control System: AutoTest Centralized Wireless

Standards: EN-60598-1, EN-60598-2-22, EN-62034, EN-300-220-1, EN-300-220-2 Luminaire: Self-Contained

Certification: CE, ENEC, KITEMARK, CIVIL DEFENSE



Electrical characteristics

Supply: 230V 50Hz<2.5W

 $\label{eq:maintained} \begin{tabular}{ll} \textbf{Maintained mode consumption: } 2,5 \ W \\ \begin{tabular}{ll} \textbf{Non-maintained mode consumption: } 0,9 \ W \\ \end{tabular}$

Working temperature: 0-40°C
Emergency lamp: 12xLED 0.5W
Emergency lumen output: 150 lm
Maintained lumen output: 90 lm

Class: II

Mode: Non-maintained / Maintained via switch-link

Power factor: - % Signaling Luminaire: -LED temperature: 4000°K

Duration: 3 h Remote control: No Charging time: 12 h

Mechanical characteristics

Housing: Polycarbonate

Battery: 3.2V-1.5Ah LFP

Diffuser: Transparent Polycarbonate **Suitable for flammable surfaces:** Yes


Finish: White RAL9003

Weight: 0,48KG

IP/IK: IP44/IK07

ATEX Envelope:

Photometric curve



Interdistance

Installation height		
2,0 m	9,14 m	6,72 m
2,5 m	9,84 m	7,61 m
3,0 m	10,34 m	8,34 m
3,5 m	10,27 m	8,95 m



LXF9150LDP3WT



ELECTROZEMPER S.A.
Avda. de la Ciencia s/n.
Parque Ind. Avanzado
13005 Ciudad Real. Spain.
Tel.: +34 902 11 11 97
Fax: +34 902 11 11 97
in fo@zemper.com

Installation characteristics

Maintained luminaires have a selector bridge to enable /	disable the maintained mode.
Installation with mounting plate.	

Possibility of installation in:

Ceiling/Wall surface.

Reccesed in ceiling.

Semi-reccesed in wall.

Possibility of connection with:

Recessed wiring.

Surface tube wiring (max. M20)

Operating characteristics

The luminaire has status LEDs, which indicates:

Status of the battery charging circuit.

Battery status (duration)

Emergency status function.

Test status.

Microprocessor controlled luminaire

The luminaire can be connected to a control unit.

When the luminaire is installed without a control unit, it performs periodic and automatic tests.

Functional test every 7 days.

Duration test every 365 days.

The test result is shown in the status indicator LEDs.

Wireless communication that allows: Communication with Control unit by wireless communication with a 868Mhz frequency system.

General Envelope data								



LXF9150LDP3WT



ELECTROZEMPER S.A.
Avda. de la Ciencia s/n.
Parque Ind. Avanzado
13005 Ciudad Real. Spain.
Tel.: +34 902 11 11 97
Fax: +34 902 11 11 97
in fo @ z e m p e r . c o m
w w w w . z e m p e r . c o m

Accessories







