

300-400-300

# **LXF9500XT**



ELECTROZEMPER S.A. Avda. de la Ciencia s/n. Parque Ind. Avanzado 13005 Ciudad Real. Spain. Tel.: +34 902 11 11 97 Fax: +34 902 11 11 97 in fo @ zem per.com w w w.zem per.com

XENA FLAT	
Graphic reference	Dimensions
	Control System: AutoTest Luminaire: Self-Contained
	Standards: EN-60598-1,   Certification: CE, ENEC     EN-60598-2-22, EN-62034   Image: Certification in the image: Certificatio in the image:
Electrical characteristics	
Supply: 230V 50Hz<2.2W	Class: II
Maintained mode consumption: - W	Mode: NM
Non-maintained mode consumption: 2,2 W	Power factor: - %
Working temperature: 0-40°C	Signaling Luminaire: -
Emergency lamp: 12 x LED 0.5W	LED temperature: 4000°K
Emergency lumen output: 450 lm	Duration: 1 h
Maintained lumen output: - Im Battery: 3.6V-1.6Ah Ni-Cd	Remote control: No   Charging time: 24 h
Mechanical characteristics	
Housing: Polycarbonate	<b>IP/IK:</b> IP44/IK07
Diffuser: Transparent Polycarbonate	Finish: White RAL9003
Suitable for flammable surfaces: Yes	Weight: 0,51KG
ATEX Envelope:	
Photometric curve	Interdistance
	Installation height
	2,0 m 10,56 m 10,42 m
90°	2,5 m 11,74 m 11,54 m
200	3,0 m 12,74 m 12,49 m
60° \30060°	3,5 m 13.62 m 13.31 m

3,5 m

13,62 m

13,31 m



## **LXF9500XT**



ELECTROZEMPER S.A. Avda. de la Ciencia s/n. Parque Ind. Avanzado 13005 Ciudad Real. Spain. Tel.: +34 902 11 11 97 Fax: +34 902 11 11 97 in fo @ z em per.com w w w.z em per.com

#### Installation characteristics

Maintained luminaires have a selector bridge to enable / disable the maintained mode. Installation with mounting plate. Possibility of installation in: Ceiling/Wall surface. Reccessed in ceiling. Semi-reccessed in wall. Possibility of connection with: Recessed wiring. Surface tube wiring (max. M20)

#### **Operating characteristics**

The luminaire has status LEDs, which indicates: Status of the battery charging circuit. Battery status (duration) Emergency status function. Test status. Microprocessor controlled luminaire that performs periodic and automatic tests. Functional test every 7 days. Duration test every 365 days. The test result is shown in the status indicator LEDs.

### General Envelope data



**LXF9500XT** 



ELECTROZEMPER S.A. Avda. de la Ciencia s/n. Parque Ind. Avanzado 13005 Ciudad Real. Spain. Tel.: +34 902 11 11 97 Fax: +34 902 11 11 97 in fo @ z em per.com w w w.z em per.com

