

LYW3300LX




ELECTROZEMPER S.A.
Avda. de la Ciencia s/n.
Parque Ind. Avanzado
13005 Ciudad Real. Spain.
Tel:: +34 902 11 11 97
Fax: +34 902 11 11 97
info@zemper.com

Graphic reference

WALYA



Dimensions



Standards: EN-60598-1, EN-60598-2-22, EN-62034

s: EN-60598-1, Certification: CE

Electrical characteristics

Supply: 230V 50Hz<1.0W

Maintained mode consumption: - W

Non-maintained mode consumption: 1,0 $\,\mathrm{W}$

Working temperature: 0-40°C Emergency lamp: 4xLED 0.5W Emergency lumen output: 300 lm Maintained lumen output: - lm Battery: 3.2V-1.5Ah LFP Class: II Mode: NM

Power factor: - % Signaling Luminaire: -LED temperature: 4000°K

Duration: 1 h **Remote control:** Yes **Charging time:** 12 h

Mechanical characteristics

Housing: Polycarbonate

Diffuser: Ambient + Directional Lens **Suitable for flammable surfaces:** Yes


IP/IK: IP42/IK04

Finish: White RAL9003

Weight: 0,18KG

ATEX Envelope:

Photometric curve



Interdistance

Installation height		
2,0 m	12,27 m	7,97 m
2,5 m	12,80 m	8,65 m
3,0 m	12,85 m	9,22 m
3,5 m	12,70 m	9,68 m



LYW3300LX



ELECTROZEMPER S.A.
Avda. de la Ciencia s/n.
Parque Ind. Avanzado
13005 Ciudad Real. Spain.
Tel.: +34 902 11 11 97
Fax: +34 902 11 11 97
info@ zemper.com
www.zemper.com

Installation characteristics

WALYA

Maintained luminaires use 4 terminals (2xL + 2xN)
Installation with mounting plate.
Possibility of installation in:
Wall surface

Possibility of connection with:

Recessed wiring.

Operating characteristics

The luminaire has status LEDs, which indicates:

Status of the battery charging circuit.

Battery status (duration)

Emergency status function.

Test status.

General Envelope data

Microprocessor controlled luminaire that performs periodic and automatic tests.

Functional test every 7 days.

Duration test every 365 days.

The test result is shown in the status indicator LEDs.

Remote control input that allows:

Put on Standby without power supply.

Restart in emergency status without power supply.

Switch on in emergency status (more than 24 h of charge)

Manual and remote duration test. (more than 24 hours of charge).

Date and time programming of the tests.

Reset of the luminaire status.