

PMV1500LX3F




ELECTROZEMPER S.A. ELECTROZEMPER S.A.
Avda. de la Ciencia s/n.
Parque Ind. Avanzado
13005 Ciudad Real. Spain.
Tel.: +34 902 11 11 97
Fax: +34 902 11 11 97
info@zemper.com

Graphic reference

MAXILUM EVO





Luminaire: Self-Contained Control System: AutoTest

Standards: EN-60598-1, EN-60598-2-22, EN-62034 Certification: CE

Supply: 230V 50Hz<9.0W

Maintained mode consumption: - W

Non-maintained mode consumption: 3.0 W Working temperature: -30°C - +25°C

Emergency lamp: 2x LEDS 10W Emergency lumen output: 1500 lm Maintained lumen output: - Im

Battery: 2x(12,8V-3.0Ah LFP)

Class: II

Mode: NM

Power factor: - % Signaling Luminaire: -

LED temperature: 4000°K

Duration: 1 h

Remote control: Yes

Charging time: 24 h

Mechanical characteristics

Envelope: Polycarbonate

Diffuser: Glass

Suitable for flammable surfaces: Yes


IP/IK: IP65/IK07

Finish: White RAL9003

Weight: 3,76KG

ATEX Envelope:

Photometric curve



Interdistance

Installation height		
2,0 m	9,79 m	8,57 m
2,5 m	12,24 m	10,71 m
3,0 m	14,69 m	12,86 m
3,5 m	17,14 m	15,00 m



PMV1500LX3F



ELECTROZEMPER S.A.
Avda. de la Ciencia s/n.
Parque Ind. Avanzado
13005 Ciudad Real. Spain.
Tel.: +34 902 11 11 97
Fax: +34 902 11 11 97
in fo@zemper.com

Installation characteristics

MAXILUM EVO

Possibility	of	instal	llation	in:

Ceiling/Wall surface.

Possibility of connection with:

Surface tube wiring.

It has 4 pre-marked entries for PG-11 (included)

Two orientable spotlights, horizontally y vertically.

Specially designed to cover large areas and / or heights.

Operating characteristics

The luminaire has status LEDs, which indicates:

Status of the battery charging circuit.

Battery status (duration)

Emergency status function.

Test status.

Microprocessor controlled luminaire that performs periodic and automatic tests.

Functional test every 7 days.

Duration test every 365 days.

The test result is shown in the status indicator LEDs.

Remote control input that allows:

Put on Standby without power supply.

Restart in emergency status without power supply.

Switch on in emergency status (more than 24 h of charge)

Manual and remote duration test. (more than 24 hours of charge).

Date and time programming of the tests.

Reset of the luminaire status.

General Envelope data		



PMV1500LX3F



ELECTROZEMPER S.A.
Avda. de la Ciencia s/n.
Parque Ind. Avanzado
13005 Ciudad Real. Spain.
Tel.: +34 902 11 11 97
Fax: +34 902 11 11 97
in fo@zemper.com
www.zemper.com

Accessories

